


**NOTES:**

1. SUBSTITUTES FOR ANY MATERIALS SHOWN MUST BE APPROVED BY THE DISTRICT.
2. ALL PIPE AND STRUCTURAL ZONES SHALL BE BACKFILLED AND COMPACTED PER STANDARD TRENCH DETAIL SD-51.
3. METER BOX SHALL BE CENTERED OVER THE COMPLETED METER AND FITTING ASSEMBLY AND TOP SHALL BE FLUSH WITH SIDEWALK, CURB, OR FINISHED GRADE.
4. METER SHALL BE PERPENDICULAR TO CURB LINE.
5. ALL FITTINGS TO CONFORM TO AMERICAN WATER WORKS ASSOCIATION STANDARD SPECIFICATIONS, CONTAINING NO LEAD.
6. ALL FITTINGS TO BE COMPRESSION JOINTS.
7. ALL COPPER TUBE BENDS TO BE SMOOTH RADIUS.

**MATERIALS:**

- ① METER BOXES PLACED IN PLANTER STRIP SHALL BE:  
 3/4" SERVICE - BROOKS 36MB BODY, 36ST LID, AND 36S COVER  
 1" SERVICE - BROOKS 37MB, 37ST LID, AND 37S COVER  
 METER BOXES PLACED IN CONCRETE SHALL BE:  
 3/4" SERVICE - DFW 36C4-12-BODY AND DFW 36C-4-LID  
 1" SERVICE - DFW 486WBC4-12-BODY AND DFW 486C-4MPP-LID
- ② ASTM B88 TYPE "K" SOFT COPPER TUBING
- ③ CORPORATION STOP, MUELLER B-25008N AWWA "CC" THREAD X COMPRESSION
- ④ CURB STOP, MUELLER B-24258N COMPRESSION X SWIVEL. QUARTER TURN WITH LOCK WINGS AND FULL PORT
- ⑤ WHEEL STOP TO BE FORD GA13-332-NL OR GA13-444-NL F.I.P X SWIVEL WITH M.I.P X MUELLER 110 COMPRESSION COUPLING (H-15428N)



**STANDARD WATER SERVICE**

**ROCKWOOD WATER PEOPLE'S UTILITY DISTRICT**  
 19601 NE HALSEY ST., PORTLAND, OR 97230-7489, OFFICE: (503) 665-4179, FAX: (503) 667-5108

DRAWN BY: J. HANSON	
DATE: MARCH 2, 2020	
SCALE: N.T.S.	DWG NO: SD-25