


CONCRETE BEARING AGAINST
UNDISTURBED SOIL
8" WATERLINE = 4.0 SF
6" WATERLINE = 2.5 SF
4" WATERLINE = 2.0 SF

GALVANIZED OR COATED STEEL
A-307 STEEL BOLT STOCK
14,000 PSI TENSILE STRENGTH
8" WATERLINE = 3/4" DIA.
6" or 4" WATERLINE = 5/8" DIA.
THREADED END

PLAN VIEW

PROFILE VIEW



RODDED VALVE

ROCKWOOD WATER PEOPLE'S UTILITY DISTRICT
19601 NE HALSEY ST., PORTLAND, OR 97230-7489, OFFICE: (503) 665-4179, FAX: (503) 667-5108

DRAWN BY: J. HUDSON	
DATE: JANUARY 2, 2015	
SCALE: N.T.S.	DWG NO: SD-32