


NOTE:
TEST COCKS FACING UP

ALL BACKFLOW ASSEMBLIES USED FOR THE PROTECTION OF POTABLE WATER MUST BE LEAD-FREE AND APPROVED BY THE OREGON HEALTH AUTHORITY

PROFILE VIEW

PLAN VIEW



2" & SMALLER DOUBLE CHECK VALVE ASSEMBLY
ROCKWOOD WATER PEOPLE'S UTILITY DISTRICT
 19601 NE HALSEY ST., PORTLAND, OR 97230-7489, OFFICE: (503) 665-4179, FAX: (503) 667-5108

DRAWN BY: J. HUDSON	
DATE: JANUARY 6, 2016	
SCALE: N.T.S.	DWG NO: SD-36