


**NOTES:**

\*PAVING PER CITY OF GRESHAM, CITY OF PORTLAND, OR MULTNOMAH COUNTY REQUIREMENTS.

1. BASE ROCK 1-1/2" - 0" CRUSHED ROCK PLACED IN 2 LIFTS, COMPACTED TO 95% OPTIMUM DENSITY.
2. 3/4" - 0" OR APPROVED IMPORTED GRANULAR BACKFILL COMPACTED TO 95% OPTIMUM DENSITY.
3. HAND TAMPED PIPE ZONE BACKFILL, APPROVED IMPORTED GRANULAR MATERIAL COMPACTED TO 95% OPTIMUM DENSITY.
4. PIPE BEDDING COMPACTED 3/4" - 0" CRUSHED ROCK OR APPROVED SAND. (SAND REQUIRED IF PIPE IS POLYBAGGED)



## STANDARD TRENCH DETAIL

**ROCKWOOD WATER PEOPLE'S UTILITY DISTRICT**

19601 NE HALSEY ST., PORTLAND, OR 97230-7489, OFFICE: (503) 665-4179, FAX: (503) 667-5108

DRAWN BY: J. HUDSON

DATE: JANUARY 2, 2015

SCALE: N.T.S.

DWG NO: SD-51