



FIRE SERVICE APPLICATION

RFM

Rockwood Control #: - RFM

Applicants must submit scalable site utility plan.

Date	Property Address		Building Permit Number	
Contact		Company		
Address, City, State, Zip				
Phone	Fax	Email		
Fire Service Specifics				
Fire Service to: ☐ Building Fire Suppression ☐ Private Fire Hydrants ☐ Other (please specify):		Will there be commercial space? ☐ Yes ☐ No		
Fire Department Requirements ☐ FDC (Fire Depart. Connection) ☐ PIV (Post Indicator Valve) ☐ Tamper Switches	I have a copy of Rockwood Water's Fire Line Standard Detail SD-35. ☐ Yes ☐ No *This detail must be used in Rockwood Water District. It can be found here: http://rwpud.org/sd35.pdf			
Fire Line Flow Requirements Fire line sizes are based on fire sprinkler system flow requirements. These requirements are made by your design engineer and the fire department.	Fire Line Size (inches) _____ Flow requirements _____ gpm Necessary Pressure (residual) _____ psi			
Public Fire Hydrants	Are you required to add fire hydrants in the public right-of-way?		☐ Yes ☐ No	How many?
	Will you need to adjust, relocate, or remove public fire hydrants?		☐ Yes ☐ No	How many?
<p style="text-align: center;"> All fire lines must be protected at the property line by a minimum of a Double Check Detector Assembly (DCDA) Installations shall be in a vault at the property line according to SD-35 If a riser room installation is requested, the riser room must be directly adjacent to the property line and the detector meter must have a touch pad remote reader mounted on the exterior of the building. </p>				