


NOTES:

1. SUBSTITUTES FOR ANY MATERIALS SHOWN MUST BE APPROVED BY THE DISTRICT.
2. ALL PIPE AND STRUCTURAL ZONES SHALL BE BACKFILLED AND COMPACTED PER STANDARD TRENCH DETAIL SD-51.
3. METER BOX SHALL BE CENTERED OVER THE COMPLETED METER AND FITTING ASSEMBLY AND TOP SHALL BE FLUSH WITH SIDEWALK, CURB, OR FINISHED GRADE.
4. METER SHALL BE PERPENDICULAR TO CURB LINE.
5. ALL FITTINGS TO CONFORM TO AMERICAN WATER WORKS ASSOCIATION STANDARD SPECIFICATIONS, CONTAINING NO LEAD.
6. ALL FITTINGS TO BE COMPRESSION JOINTS.
7. ALL COPPER TUBE BENDS TO BE SMOOTH RADIUS.
8. PRIVATE SIDE PIPE MATERIAL MAY NOT BE GALVANIZED STEEL.

MATERIALS:

- ① METER BOX SHALL BE:
5/8", 3/4", AND 1" SERVICE:
DFW 486WBC4-12-BODY AND DFW 486C-4MP-NHK-LID
- ② ASTM B88 TYPE "K" SOFT COPPER TUBING
- ③ CORPORATION STOP, MUELLER B-25008N AWWA "CC" THREAD X COMPRESSION
- ④ CURB STOP, MUELLER B-24258N COMPRESSION X SWIVEL. QUARTER TURN WITH LOCK WINGS AND FULL PORT
- ⑤ WHEEL STOP TO BE FORD GA13-332-NL OR GA13-444-NL F.I.P X SWIVEL WITH M.I.P X MUELLER 110 COMPRESSION COUPLING (H-15428N)



STANDARD WATER SERVICE

ROCKWOOD WATER PEOPLE'S UTILITY DISTRICT

19601 NE HALSEY ST., PORTLAND, OR 97230-7489, OFFICE: (503) 665-4179, FAX: (503) 667-5108

DRAWN BY: J. HANSON

DATE: JANUARY 25, 2023

SCALE: N.T.S.

DWG NO: SD-25