


NOTES:

1. FIRE HYDRANT SHALL BE DRY BARREL TYPE AND CONFORM TO AWWA STANDARD C502. HYDRANTS ARE TO BE YELLOW AND THE DEPTH OF BURY IS TO BE DETERMINED IN THE FIELD. HYDRANT SHALL BE EJIW 5CD250. SUITABLE SUBSTITUTE MAY BE THE WATEROUS PACER BY DISTRICT APPROVAL.
2. 5-1/4" VALVE OPENING.
3. OPERATING AND NOZZLE NUTS SHALL BE 1-1/2" POINT TO FLAT AT BASE OF NUT.
4. OPERATING NUT TO OPEN COUNTER CLOCKWISE.
5. ALL JOINTS TO BE RESTRAINED AS SHOWN, WITH FLANGED CONNECTIONS AND MECHANICAL JOINTS (GRIP RINGS OR MEGALUGS).
6. FIRE HYDRANTS MUST BE KEPT AT A MINIMUM DISTANCE OF 4 FEET FROM ALL POWER POLES. **EXCEPTION: WHERE CONDITIONS DO NOT PERMIT, A CLEARANCE OF NOT LESS THAN 3 FEET IS ALLOWED.**



FIRE HYDRANT ASSEMBLY

ROCKWOOD WATER PEOPLE'S UTILITY DISTRICT

19601 NE HALSEY ST., PORTLAND, OR 97230-7489, OFFICE: (503) 665-4179, FAX: (503) 667-5108

DRAWN BY: J. HANSON

DATE: JUNE 27, 2024

SCALE: N.T.S.

DWG NO: SD-5